

BFWD MONTHLY OPERATIONS SUMMARY			
January-17			
	January-17	December 16	January 16
PRODUCTION:			
WELL #2 (WEST)	0	0	21,400
WELL #4 (EAST)	1,371,887	1,364,994	1,360,968
WELL #6 (EAST)	349,789	370,687	184,331
BFWD TOTAL	1,721,676	1,735,681	1,566,699
PRODUCTION:			
EAST SECTOR	1,721,676	1,735,680	1,545,299
WEST SECTOR	0	0	21,400
TRANSFER (E>W)	285,382	307,126	272,387
TRANSFER (TANK-2 - TANK-5)	76,764	43,159	20,016
TRANSFER (TANK-5 - TANK-2)	69,786	22,259	20,454
WATER SUPPLIED TO:			
EAST SECTOR	1,436,294	1,428,555	1,272,912
WEST SECTOR	285,382	307,126	293,787
OPERATING TIMES:			
WELL #2	0	0	22
WELL #4	744	733	746
WELL #6	244	258	129
TOTAL HOURS	987	991	897
GALS / HOUR	1,744	1,752	1,748
WELL #2 AVERAGE GPM	0.0	0.0	16.4
WELL #4 AVERAGE GPM	30.7	31.0	30.4
WELL #6 AVERAGE GPM	23.9	24.0	23.8
WATER QUALITY TESTS:			
CL2 RATE (p/d)	0.20	0.20	0.20
BFWD FREE CL2 (mg/L)	0.65	0.45	0.56
IND. LAB COL. TEST	PASS	PASS	PASS
NON-CONSUMPTION:			
STORAGE, T-2	34,584	33,150	33,160
STORAGE, T-4	167,322	162,083	157,949
STORAGE, T-5	174,328	189,213	178,656
LOSS TO BREAKS	104,319	170,000	69,184
LOSS TO WASTE	500	500	500
TOTAL N-C	104,819	170,500	500
CUSTOMER STATUS:			
EAST TOTAL HOMES	216	216	216
EAST COMMERCIAL ACCTS.	3	3	3
EAST SERVICES IN-USE	211	211	211
WEST TOTAL HOMES	74	74	74
WEST SERVICES IN-USE	73	73	73
TOTAL BFWD SERV IN-USE	287	287	287
CONSUMPTION:			
BFWD NET TOTAL	1,616,857	1,565,181	1,497,015
BFWD PER SERVICE (IN-USE)	5,634	5,454	5,216
BFWD w/o COMMERCIAL ACCTS.	5,605	5,409	4,493
BF INN as % of total BFWD use	0.9%	1.0%	14.4%
NOTE: COMMERCIAL ACCTS.			
1) BF INN	14,000	16,000	215,000
2) BF APTS	11,000	13,000	6,000
3) BF FIRE STATION	0	0	0
STEVENSONS DAM LEVEL:	Flowing Over Spillway		65.3

TIMBER TRAIL ROAD TRANSFER STATION REPORT

January-17

DATE	DAY	METER READING	TRANSFERED GALLONS	TANK 5 LEVEL IN FT	TANK 5 LEVEL IN GALS	COMMENTS
1	SU	951,794	0	29.0	174,464	
2	M	951,838	0	29.0	174,464	
3	T	951,869	7,219	27.8	167,245	Trans 5 - 2
4	W	951,920	0	27.8	167,245	
5	TH	951,984	0	27.8	167,245	
6	F	952,053	0	27.8	167,245	
7	S	956,851	13,837	30.1	181,082	Trans 2 - 5
8	SU	956,883	0	30.1	181,082	
9	M	956,905	20,455	26.7	160,627	Trans 5 - 2
10	T	956,934	28,275	22.0	132,352	Trans 5 - 2
11	W	964,130	7,219	23.2	139,571	Trans 2 - 5
12	TH	1,001,135	48,370	31.3	188,301	Trans 2 - 5
13	F	1,001,171	0	31.3	188,301	
14	S	1,001,205	0	31.3	188,301	
15	SU	1,001,240	0	31.3	188,301	
16	M	1,001,275	0	31.3	188,301	
17	T	1,001,314	13,837	29.0	174,464	Trans 5 - 2
18	W	1,001,348	0	29.0	174,464	
19	TH	1,001,374	0	29.0	174,464	
20	F	1,001,404	0	29.0	174,464	
21	S	1,001,443	0	29.0	174,464	
22	SU	1,001,481	0	29.0	174,464	
23	M	1,001,512	0	29.0	174,464	
24	T	1,001,550	0	29.0	174,464	
25	W	1,001,611	0	29.0	174,464	
26	TH	1,001,674	0	29.0	174,464	
27	F	1,006,764	7,338	30.1	181,082	Trans 2 - 5
28	S	1,006,802	0	30.1	181,082	
29	SU	1,006,827	0	30.1	181,082	
30	M	1,006,853	0	30.1	181,082	
31	T	1,006,883	0	30.1	181,082	
<i>LAST WATER METER READING OF PREVIOUS MONTH</i>						1,951,759
<i>LAST T-5 STORAGE (GALS) READING OF PREVIOUS MONTH</i>						174,464
TOTAL GALLONS TRANSFERRED FROM TANK# 5 - TANK# 2						69,786
TOTAL GALLONS TRANSFERRED FROM TANK# 2 - TANK# 5						76,764
TANK #5 AVERAGE DAILY STORAGE (GALS)						174,328

FOREST ESTATES ROAD TRANSFER STATION REPORT

January-17

DATE	DAY	METER READING	RUN TIME MINUTES	TRANSFERED GALLONS	TANK 4 LEVEL IN FT	TANK 4 LEVEL IN GALS	COMMENTS
1	SU	8,743,966	180	8,550.0	28.5	171,456	
2	M	8,752,110	180	8,144.0	28.5	171,456	
3	T	8,761,056	180	8,946.0	28.5	171,456	
4	W	8,769,710	180	8,654.0	28.5	171,456	
5	TH	8,778,352	180	8,642.0	28.5	171,456	
6	F	8,786,936	180	8,584.0	28.5	171,456	
7	S	8,795,740	180	8,804.0	28.5	171,456	
8	SU	8,804,464	180	8,724.0	28.5	171,456	
9	M	8,812,354	180	7,890.0	28.5	171,456	
10	T	8,812,354	0	0.0	28.5	171,456	
11	W	8,812,354	0	0.0	26.2	157,619	
12	TH	8,812,354	0	0.0	23.9	143,782	
13	F	8,832,800	420	20,446.0	25.0	150,400	
14	S	8,844,486	240	11,686.0	26.2	157,619	
15	SU	8,856,164	240	11,678.0	26.2	157,619	
16	M	8,867,578	240	11,414.0	26.2	157,619	
17	T	8,879,100	240	11,522.0	26.2	157,619	
18	W	8,890,634	240	11,534.0	26.2	157,619	
19	TH	8,902,234	240	11,600.0	27.3	164,237	
20	F	8,913,766	240	11,532.0	27.3	164,237	
21	S	8,925,368	240	11,602.0	27.3	164,237	
22	SU	8,936,632	240	11,264.0	27.3	164,237	
23	M	8,948,392	240	11,760.0	27.3	164,237	
24	T	8,959,664	240	11,272.0	28.5	171,456	
25	W	8,968,344	180	8,680.0	28.5	171,456	
26	TH	8,977,050	180	8,706.0	29.6	178,074	
27	F	8,985,816	180	8,766.0	29.6	178,074	
28	S	8,994,582	180	8,766.0	29.6	178,074	
29	SU	9,003,340	180	8,758.0	29.6	178,074	
30	M	9,012,034	180	8,694.0	29.6	178,074	
31	T	9,020,798	180	8,764.0	29.6	178,074	

<i>LAST WATER METER READING OF PREVIOUS MONTH</i>	8,735,416
<i>LAST T-4 STORAGE (GALS) READING OF PREVIOUS MONTH</i>	164,237

TOTAL RUN TIME (min)	5,940
TOTAL GALLONS TRANSFERED	285,382

AVERAGE PUMP RATE - GPM	48.0
AVERAGE PUMP RATE - GPH	2,882.6
AVERAGE DAILY STORAGE (GALS)	167,322

MONTHLY OPERATIONS REPORT FOR WELL #2

January-17

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	COMMENTS
1	SU				
2	M				
3	T				
4	W				
5	TH				
6	F				
7	S				
8	SU				
9	M				
10	T				
11	W				
12	TH				
13	F				
14	S				
15	SU				
16	M				
17	T				
18	W				
19	TH				
20	F				
21	S				
22	SU				
23	M				
24	T				
25	W				
26	TH				
27	F				
28	S				
29	SU				
30	M				
31	T				
<i>LAST WATER METER READING OF PREVIOUS MONTH</i> <i>LAST HOUR METER READING OF PREVIOUS MONTH</i>					0 0.0
Total Monthly Production (Gallons) Total Pump Run time (Hours) Average GPH Rate of Production					0 0.0 #DIV/0!
Average Daily Production (Gallons) Percent of time in operation Average GPM Rate of Production					0 0% #DIV/0!

MONTHLY OPERATIONS REPORT FOR WELL #4

January-17

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	TANK 2 LEVEL IN FT	TANK 2 LEVEL IN GALS	COMMENTS
1	SU	30,395,680	75,578.8	145	11.4	30,000	
2	M	30,438,816	75,602.5	145	11.4	30,000	
3	T	30,482,016	75,626.3	145	11.4	30,000	
4	W	30,526,624	75,650.1	145	12.5	32,895	
5	TH	30,574,616	75,675.0	145	12.5	32,895	
6	F	30,617,783	75,699.2	145	12.5	32,895	
7	S	30,663,912	75,722.8	145	13.7	36,053	
8	SU	30,707,151	75,746.1	145	13.7	36,053	
9	M	30,750,312	75,770.4	145	12.5	32,895	
10	T	30,792,312	75,792.3	145	12.5	32,895	
11	W	30,838,862	75,818.2	145	14.8	38,948	
12	TH	30,882,493	75,842.0	145	14.8	38,948	
13	F	30,926,187	75,865.7	145	12.5	32,895	
14	S	30,969,518	75,889.4	145	12.5	32,895	
15	SU	31,016,900	75,913.3	145	11.4	30,000	
16	M	31,059,985	75,937.6	145	10.1	26,579	
17	T	31,103,185	75,961.5	145	12.5	32,895	
18	W	31,147,433	75,985.1	145	13.7	36,053	
19	TH	31,189,960	76,008.6	145	13.7	36,053	
20	F	31,234,282	76,032.7	145	13.7	36,053	
21	S	31,281,226	76,057.2	145	14.5	38,158	
22	SU	31,324,508	76,081.5	145	13.7	36,053	
23	M	31,367,641	76,105.0	145	12.5	32,895	
24	T	31,413,244	76,129.7	145	12.5	32,895	
25	W	31,458,173	76,154.1	145	13.7	36,053	
26	TH	31,501,205	76,177.6	145	16.0	42,106	
27	F	31,545,243	76,201.4	145	13.7	36,053	
28	S	31,590,586	76,225.1	145	14.8	38,948	
29	SU	31,633,771	76,249.3	145	14.8	38,948	
30	M	31,676,974	76,273.1	145	13.7	36,053	
31	T	31,724,299	76,298.1	145	13.7	36,053	
<i>LAST WATER METER READING OF PREVIOUS MONTH</i> <i>LAST HOUR METER READING OF PREVIOUS MONTH</i> <i>LAST T-2 STORAGE (GALS) READING OF PREVIOUS MONTH</i>							30,352,412 75,554.3 30,000
Total Monthly Production (Gallons)							1,371,887
Total Pump Run time (Hours)							743.8
Average GPH Rate of Production							1,844
Average Daily Production (Gallons)							44,254
Percent of time in operation							100%
Average daily storage (gals)							34,584
Average GPM Rate of Production							30.7

MONTHLY OPERATIONS REPORT FOR WELL #6

January-17

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	GPH RATE SET	WELL TIMER COMMENTS
1	SU	104,803,020	60,217.0	250	MAX	
2	M	104,811,218	60,222.6	250	MAX	
3	T	104,819,858	60,228.6	250	MAX	
4	W	104,828,255	60,234.5	250	MAX	
5	TH	104,836,650	60,240.3	250	MAX	
6	F	104,847,172	60,247.6	250	MAX	
7	S	104,857,651	60,254.9	250	MAX	
8	SU	104,864,600	60,259.7	250	MAX	
9	M	104,871,650	60,264.5	250	MAX	
10	T	104,904,008	60,287.0	250	MAX	
11	W	104,941,802	60,313.5	250	MAX	
12	TH	104,974,334	60,336.5	250	MAX	
13	F	104,985,870	60,344.5	250	MAX	
14	S	104,992,890	60,349.3	250	MAX	
15	SU	104,999,909	60,354.2	250	MAX	
16	M	105,010,134	60,361.3	250	MAX	
17	T	105,020,332	60,368.4	250	MAX	
18	W	105,030,508	60,375.4	250	MAX	
19	TH	105,040,686	60,382.5	250	MAX	
20	F	105,050,869	60,389.6	250	MAX	
21	S	105,061,250	60,396.1	250	MAX	
22	SU	105,071,330	60,403.8	250	MAX	
23	M	105,081,410	60,410.8	250	MAX	
24	T	105,091,388	60,417.9	250	MAX	
25	W	105,101,733	60,425.0	250	MAX	
26	TH	105,111,850	60,432.1	250	MAX	
27	F	105,118,801	60,436.9	250	MAX	
28	S	105,125,782	60,441.7	250	MAX	
29	SU	105,132,556	60,446.8	250	MAX	
30	M	105,139,750	60,451.5	250	MAX	
31	T	105,146,563	60,456.2	250	MAX	

LAST WATER METER READING OF PREVIOUS MONTH 104,796,774

LAST HOUR METER READING OF PREVIOUS MONTH 60,212.7

TOTAL MONTHLY PRODUCTION (GALS) 349,789

TOTAL PUMP RUN TIME (HOURS) 243.5

AVERAGE GPH RATE OF PRODUCTION 1,437

AVERAGE DAILY PRODUCTION (GALS) 11,284

PERCENT OF TIME IN OPERATION 33%

AVERAGE GPM RATE OF PRODUCTION 23.9