

BFWD MONTHLY OPERATIONS SUMMARY			
August-16			
	August-16	July-16	August-15
PRODUCTION:			
WELL #2 (WEST)	0	0	0
WELL #4 (EAST)	1,368,424	1,369,315	1,361,480
WELL #6 (EAST)	299,005	329,921	285,329
BFWD TOTAL	1,667,429	1,699,236	1,646,809
PRODUCTION:			
EAST SECTOR	1,667,429	1,699,236	1,646,809
WEST SECTOR	0	0	0
TRANSFER (E>W)	294,104	289,245	317,410
TRANSFER (TANK-2 - TANK-5)	49,933	14,544	34,289
TRANSFER (TANK-5 - TANK-2)	22,259	27,674	42,112
WATER SUPPLIED TO:			
EAST SECTOR	1,373,325	1,409,991	1,329,399
WEST SECTOR	294,104	289,245	317,410
OPERATING TIMES:			
WELL #2	0	0	0
WELL #4	743	743	743
WELL #6	206	228	199
TOTAL HOURS	950	971	941
GALS / HOUR	1,756	1,750	1,749
WELL #2 AVERAGE GPM	0.0	0.0	0.0
WELL #4 AVERAGE GPM	30.7	30.7	30.6
WELL #6 AVERAGE GPM	24.1	24.1	23.9
WATER QUALITY TESTS:			
CL2 RATE (p/d)	0.20	0.20	0.20
BFWD FREE CL2 (mg/L)	0.30	0.31	0.65
IND. LAB COL. TEST	PASS	PASS	PASS
NON-CONSUMPTION:			
STORAGE, T-2	33,617	32,428	28,650
STORAGE, T-4	111,568	118,244	148,838
STORAGE, T-5	182,130	169,651	177,375
LOSS TO BREAKS	0	0	100,000
LOSS TO WASTE	500	500	500
TOTAL N-C	500	500	100,500
CUSTOMER STATUS:			
EAST TOTAL HOMES	216	216	216
EAST COMMERCIAL ACCTS.	3	3	3
EAST SERVICES IN-USE	215	215	213
WEST TOTAL HOMES	74	74	74
WEST SERVICES IN-USE	73	73	72
TOTAL BFWD SERV IN-USE	291	291	288
CONSUMPTION:			
BFWD NET TOTAL	1,666,929	1,698,736	1,546,309
BFWD PER SERVICE (IN-USE)	5,728	5,838	5,369
BFWD w/o COMMERCIAL ACCTS.	5,555	5,680	5,313
BF INN as % of total BFWD use	1.7%	2.1%	1.4%
NOTE: COMMERCIAL ACCTS.			
1) BF INN	29,000	35,000	22,000
2) BF APTS	38,000	28,000	10,000
3) BF FIRE STATION	0	0	0
STEVENSONS DAM LEVEL:	Flowing Over Spillway		615.2

TIMBER TRAIL ROAD TRANSFER STATION REPORT

August-16

DATE	DAY	METER READING	TRANSFERED GALLONS	TANK 5 LEVEL IN FT	TANK 5 LEVEL IN GALS	COMMENTS
1	M	1,808,913		26.7	160,627	
2	T	1,808,403	6,618	27.8	167,245	Trans 2 - 5
3	W	1,808,428		27.8	167,245	
4	TH	1,813,848	7,219	29.0	174,464	Trans 2 - 5
5	F	1,813,878		29.0	174,464	
6	S	1,818,870	6,618	30.1	181,082	Trans 2 - 5
7	SU	1,830,335	7,219	31.3	188,301	Trans 2 - 5
8	M	1,830,361		31.3	188,301	
9	T	1,830,383		31.3	188,301	
10	W	1,830,411		31.3	188,301	
11	TH	1,830,433		31.3	188,301	
12	F	1,830,462		31.3	188,301	
13	S	1,830,493		31.3	188,301	
14	SU	1,830,521		31.3	188,301	
15	M	1,830,546	13,837	29.0	174,464	Trans 5 - 2
16	T	1,830,572		29.0	174,464	
17	W	1,830,603	1,203	28.8	173,261	Trans 5 - 2
18	TH	1,830,629		28.8	173,261	
19	F	1,837,506	7,821	30.1	181,082	Trans 2 - 5
20	S	1,837,534		30.1	181,082	
21	SU	1,843,964	7,219	31.3	188,301	Trans 2 - 5
22	M	1,843,989		31.3	188,301	
23	T	1,844,015	7,219	30.1	181,082	Trans 5 - 2
24	W	1,844,048		30.1	181,082	
25	TH	1,849,582	7,219	31.3	188,301	Trans 2 - 5
26	F	1,849,615		31.3	188,301	
27	S	1,849,647		31.3	188,301	
28	SU	1,849,675		31.3	188,301	
29	M	1,849,699		31.3	188,301	
30	T	1,849,732		31.3	188,301	
31	W	1,849,763		31.3	188,301	
<i>LAST WATER METER READING OF PREVIOUS MONTH</i>						1,805,872
<i>LAST T-5 STORAGE (GALS) READING OF PREVIOUS MONTH</i>						160,627
TOTAL GALLONS TRANSFERRED FROM TANK# 5 - TANK# 2						22,259
TOTAL GALLONS TRANSFERRED FROM TANK# 2 - TANK# 5						49,933
TANK #5 AVERAGE DAILY STORAGE (GALS)						182,130

FOREST ESTATES ROAD TRANSFER STATION

August-16

DATE	DAY	METER READING	RUN TIME MINUTES	GALLONS TRANSFERED	TANK 4 LEVEL IN FT	TANK 4 LEVEL IN GALS	COMMENTS
1	M	7,212,894	180	8,949.0	19.30	116,109	
2	T	7,222,286	180	9,392.0	19.30	116,109	
3	W	7,231,701	180	9,415.0	19.30	116,109	
4	TH	7,241,078	180	9,377.0	19.30	116,109	
5	F	7,250,480	180	9,402.0	19.30	116,109	
6	S	7,259,976	180	9,496.0	19.30	116,109	
7	SU	7,269,264	180	9,288.0	19.30	116,109	
8	M	7,278,601	180	9,337.0	19.30	116,109	
9	T	7,287,938	180	9,337.0	19.30	116,109	
10	W	7,297,394	180	9,456.0	19.30	116,109	
11	TH	7,306,768	180	9,374.0	19.30	116,109	
12	F	7,316,232	180	9,464.0	19.30	116,109	
13	S	7,325,624	180	9,392.0	19.30	116,109	
14	SU	7,335,110	180	9,486.0	19.30	116,109	
15	M	7,344,035	180	8,925.0	19.30	116,109	
16	T	7,353,313	180	9,278.0	19.30	116,109	
17	W	7,362,623	180	9,310.0	19.30	116,109	
18	TH	7,362,623	0	0.0	19.30	116,109	POWER OUTAGE
19	F	7,372,054	180	9,431.0	18.1	108,890	
20	S	7,372,054	0	0.0	15.8	95,053	POWER OUTAGE
21	SU	7,381,534	180	9,480.0	15.8	95,053	
22	M	7,393,974	240	12,440.0	15.8	95,053	
23	T	7,406,354	240	12,380.0	15.8	95,053	
24	W	7,419,167	240	12,813.0	15.8	95,053	
25	TH	7,431,832	240	12,665.0	17.0	102,272	
26	F	7,444,540	240	12,708.0	18.1	108,890	
27	S	7,457,181	240	12,641.0	18.1	108,890	
28	SU	7,469,826	240	12,645.0	19.3	116,109	
29	M	7,482,160	240	12,334.0	19.3	116,109	
30	T	7,494,574	240	12,414.0	19.3	116,109	
31	W	7,506,998	240	12,424.0	19.3	116,109	

<i>LAST WATER METER READING OF PREVIOUS MONTH</i>	7,203,894
<i>LAST T-4 STORAGE (GALS) READING OF PREVIOUS MONTH</i>	116,109

TOTAL RUN TIME (min)	5,820
TOTAL GALLONS TRANSFERED	294,104

AVERAGE PUMP RATE - GPM	50.5
AVERAGE PUMP RATE - GPH	3,032.0
AVERAGE DAILY STORAGE (GALS)	111,568

MONTHLY OPERATIONS REPORT FOR WELL #2

August-16

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	COMMENTS
1	M				SHUTDOWN
2	T				SHUTDOWN
3	W				SHUTDOWN
4	TH				SHUTDOWN
5	F				SHUTDOWN
6	S				SHUTDOWN
7	SU				SHUTDOWN
8	M				SHUTDOWN
9	T				SHUTDOWN
10	W				SHUTDOWN
11	TH				SHUTDOWN
12	F				SHUTDOWN
13	S				SHUTDOWN
14	SU				SHUTDOWN
15	M				SHUTDOWN
16	T				SHUTDOWN
17	W				SHUTDOWN
18	TH				SHUTDOWN
19	F				SHUTDOWN
20	S				SHUTDOWN
21	SU				SHUTDOWN
22	M				SHUTDOWN
23	T				SHUTDOWN
24	W				SHUTDOWN
25	TH				SHUTDOWN
26	F				SHUTDOWN
27	S				SHUTDOWN
28	SU				SHUTDOWN
29	M				SHUTDOWN
30	T				SHUTDOWN
31	W				SHUTDOWN

<i>LAST WATER METER READING OF PREVIOUS MONTH</i>	0
<i>LAST HOUR METER READING OF PREVIOUS MONTH</i>	0.0

Total Monthly Production (Gallons)	0
Total Pump Run time (Hours)	0.0
Average GPH Rate of Production	0
Average Daily Production (Gallons)	0
Percent of time in operation	0%
Average GPM Rate of Production	0.0

MONTHLY OPERATIONS REPORT FOR WELL #4

August-16

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	TANK 2 LEVEL IN FT	TANK 2 LEVEL IN GALS	COMMENTS
1	M	23,639,846	71,918.4	145	13.7	36,053	
2	T	23,864,142	71,942.3	145	13.7	36,053	
3	W	23,730,585	71,967.1	145	14.8	38,948	
4	TH	23,773,706	71,991.0	145	12.5	32,895	
5	F	23,816,991	72,014.6	145	13.7	36,053	
6	S	23,863,100	72,038.1	145	14.8	38,948	
7	SU	23,906,221	72,062.7	145	12.5	32,895	
8	M	23,953,011	72,088.5	145	12.5	32,895	
9	T	23,995,816	72,111.8	145	13.7	36,053	
10	W	24,041,398	72,136.0	145	14.8	38,948	
11	TH	24,083,058	72,159.2	145	14.8	38,948	
12	F	24,126,745	72,183.0	145	13.7	36,053	
13	S	24,173,386	72,207.6	145	13.7	36,053	
14	SU	24,216,600	72,231.4	145	13.7	36,053	
15	M	24,259,745	72,255.1	145	9.0	23,684	
16	T	24,302,732	72,278.5	145	11.5	30,263	
17	W	24,347,703	72,302.9	145	13.7	36,053	
18	TH	24,392,089	72,327.0	145	14.8	38,948	
19	F	24,435,899	72,350.9	145	14.8	38,948	
20	S	24,478,900	72,373.1	145	16.0	42,106	
21	SU	24,522,116	72,397.6	145	11.4	30,000	
22	M	24,565,300	72,421.1	145	9.0	23,684	
23	T	24,609,737	72,445.1	145	9.0	23,684	
24	W	24,653,995	72,469.1	145	12.5	32,895	
25	TH	24,698,079	72,493.0	145	12.5	32,895	
26	F	24,741,843	72,516.8	145	12.5	32,895	
27	S	24,786,355	72,539.5	145	13.7	36,053	
28	SU	24,829,590	72,563.5	145	12.5	32,895	
29	M	24,873,690	72,588.6	145	9.0	23,684	
30	T	24,920,384	72,613.4	145	10.1	26,579	
31	W	24,965,070	72,637.6	145	11.4	30,000	
<i>LAST WATER METER READING OF PREVIOUS MONTH</i> <i>LAST HOUR METER READING OF PREVIOUS MONTH</i> <i>LAST T-2 STORAGE (GALS) READING OF PREVIOUS MONTH</i>							23,596,646 71,894.2 38,948
Total Monthly Production (Gallons) Total Pump Run time (Hours) Average GPH Rate of Production							1,368,424 743.4 1,841
Average Daily Production (Gallons) Percent of time in operation Average daily storage (gals) Average GPM Rate of Production							44,143 100% 33,617 30.7

MONTHLY OPERATIONS REPORT FOR WELL #6

August-16

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	GPH RATE SET	WELL TIMER COMMENTS
1	M	103,477,368	59,229.2	250	MAX	
2	T	103,490,181	59,308.1	250	MAX	
3	W	103,502,584	59,316.7	250	MAX	
4	TH	103,512,966	59,323.9	250	MAX	
5	F	103,523,839	59,331.4	250	MAX	
6	S	103,535,360	59,339.8	250	MAX	
7	SU	103,546,880	59,347.2	250	MAX	
8	M	103,561,280	59,357.4	250	MAX	
9	T	103,570,930	59,364.0	250	MAX	
10	W	103,580,699	59,370.8	250	MAX	
11	TH	103,586,932	59,375.1	250	MAX	
12	F	103,592,555	59,378.9	250	MAX	
13	S	103,599,939	59,383.2	250	MAX	
14	SU	103,605,699	59,387.1	250	MAX	
15	M	103,611,459	59,391.9	250	MAX	
16	T	103,618,694	59,396.8	250	MAX	
17	W	103,627,868	59,403.2	250	MAX	
18	TH	103,637,758	59,410.0	250	MAX	
19	F	103,644,425	59,414.6	250	MAX	
20	S	103,649,682	59,418.1	250	MAX	
21	SU	103,658,322	59,424.2	250	MAX	
22	M	103,666,962	59,430.1	250	MAX	
23	T	103,677,801	59,437.6	250	MAX	
24	W	103,692,542	59,447.8	250	MAX	
25	TH	103,705,480	59,456.7	250	MAX	
26	F	103,714,753	59,463.1	250	MAX	
27	S	103,725,290	59,471.0	250	MAX	
28	SU	103,735,378	59,478.0	250	MAX	
29	M	103,745,458	59,484.4	250	MAX	
30	T	103,764,853	59,491.3	250	MAX	
31	W	103,764,853	59,497.7	250	MAX	

LAST WATER METER READING OF PREVIOUS MONTH 103,465,848

LAST HOUR METER READING OF PREVIOUS MONTH 59,291.3

TOTAL MONTHLY PRODUCTION (GALS) 299,005

TOTAL PUMP RUN TIME (HOURS) 206.4

AVERAGE GPH RATE OF PRODUCTION 1,449

AVERAGE DAILY PRODUCTION (GALS) 9,645

PERCENT OF TIME IN OPERATION 28%

AVERAGE GPM RATE OF PRODUCTION 24.1