

BFWD MONTHLY OPERATIONS SUMMARY			
September-16			
	September-16	August-16	September-15
PRODUCTION:			
WELL #2 (WEST)	0	0	0
WELL #4 (EAST)	1,373,340	1,368,424	1,317,698
WELL #6 (EAST)	316,309	299,005	259,789
BFWD TOTAL	1,689,649	1,667,429	1,577,487
PRODUCTION:			
EAST SECTOR	1,689,649	1,667,429	1,577,487
WEST SECTOR	0	0	0
TRANSFER (E>W)	391,451	294,104	256,747
TRANSFER (TANK-2 - TANK-5)	11,430	49,933	57,152
TRANSFER (TANK-5 - TANK-2)	18,649	22,259	39,104
WATER SUPPLIED TO:			
EAST SECTOR	1,298,198	1,373,325	1,320,740
WEST SECTOR	391,451	294,104	256,747
OPERATING TIMES:			
WELL #2	0	0	0
WELL #4	719	743	721
WELL #6	218	206	181
TOTAL HOURS	937	950	902
GALS / HOUR	1,803	1,756	1,750
WELL #2 AVERAGE GPM	0.0	0.0	0.0
WELL #4 AVERAGE GPM	31.8	30.7	30.5
WELL #6 AVERAGE GPM	24.1	24.1	23.9
WATER QUALITY TESTS:			
CL2 RATE (p/d)	0.20	0.20	0.20
BFWD FREE CL2 (mg/L)	0.56	0.30	0.60
IND. LAB COL. TEST	PASS	PASS	PASS
NON-CONSUMPTION:			
STORAGE, T-2	30,781	33,617	34,167
STORAGE, T-4	138,157	111,568	178,274
STORAGE, T-5	188,642	182,130	171,436
LOSS TO BREAKS	41,511	0	21,056
LOSS TO WASTE	500	500	500
TOTAL N-C	42,011	500	21,556
CUSTOMER STATUS:			
EAST TOTAL HOMES	216	216	216
EAST COMMERCIAL ACCTS.	3	3	3
EAST SERVICES IN-USE	213	215	213
WEST TOTAL HOMES	74	74	74
WEST SERVICES IN-USE	73	73	72
TOTAL BFWD SERV IN-USE	289	291	288
CONSUMPTION:			
BFWD NET TOTAL	1,647,638	1,666,929	1,555,931
BFWD PER SERVICE (IN-USE)	5,701	5,728	5,403
BFWD w/o COMMERCIAL ACCTS.	5,556	5,555	5,330
BF INN as % of total BFWD use	2.5%	1.7%	1.7%
NOTE: COMMERCIAL ACCTS.			
1) BF INN	42,000	29,000	26,000
2) BF APTS	15,000	38,000	11,000
3) BF FIRE STATION	1,689	0	0
STEVENSONS DAM LEVEL:	Flowing Over Spillway		615.3

TIMBER TRAIL ROAD TRANSFER STATION REPORT

September-16

DATE	DAY	METER READING	TRANSFERED GALLONS	TANK 5 LEVEL IN FT	TANK 5 LEVEL IN GALS	COMMENTS
1	TH	1,849,792		31.3	188,301	
2	F	1,849,818		31.3	188,301	
3	S	1,849,845		31.3	188,301	
4	SU	1,849,878		31.3	188,301	
5	M	1,849,901		31.3	188,301	
6	T	1,849,933		31.3	188,301	
7	W	1,849,964		31.3	188,301	
8	TH	1,849,992	7,219	30.1	181,082	Trans 5 - 2
9	F	1,850,022		30.1	181,082	
10	S	1,850,057		30.1	181,082	
11	SU	1,863,099	11,430	32.0	192,512	Trans 2 - 5
12	M	1,863,123		32.0	192,512	
13	T	1,863,157		32.0	192,512	
14	W	1,863,189		32.0	192,512	
15	TH	1,863,220		32.0	192,512	
16	F	1,863,245		32.0	192,512	
17	S	1,863,272		32.0	192,512	
18	SU	1,863,305		32.0	192,512	
19	M	1,869,953		32.0	192,512	
20	T	1,869,978		32.0	192,512	
21	W	1,870,002		32.0	192,512	
22	TH	1,870,033	4,211	31.3	188,301	Trans 5 - 2
23	F	1,870,061		31.3	188,301	
24	S	1,870,096		31.3	188,301	
25	SU	1,870,110		31.3	188,301	
26	M	1,870,150		31.3	188,301	
27	T	1,870,179		31.3	188,301	
28	W	1,870,209		31.3	188,301	
29	TH	1,870,239	7,219	30.1	181,082	Trans 5 - 2
30	F	1,870,266		30.1	181,082	
<i>LAST WATER METER READING OF PREVIOUS MONTH</i>						1,849,763
<i>LAST T-5 STORAGE (GALS) READING OF PREVIOUS MONTH</i>						188,301
TOTAL GALLONS TRANSFERRED FROM TANK# 5 - TANK# 2						18,649
TOTAL GALLONS TRANSFERRED FROM TANK# 2 - TANK# 5						11,430
TANK #5 AVERAGE DAILY STORAGE (GALS)						188,642

FOREST ESTATES ROAD TRANSFER STATION REPORT

September-16

DATE	DAY	METER READING	RUN TIME MINUTES	TRANSFERED GALLONS	TANK 4 LEVEL IN FT	TANK 4 LEVEL IN GALS	COMMENTS
1	TH	7,519,411	240	12,413.0	20.4	122,726	
2	F	7,531,727	240	12,316.0	20.4	122,726	
3	S	7,544,135	240	12,408.0	21.6	129,946	
4	SU	7,556,483	240	12,348.0	21.6	129,946	
5	M	7,569,389	240	12,906.0	21.6	129,946	
6	T	7,581,389	240	12,000.0	14.7	88,435	
7	W	7,594,196	240	12,807.0	14.7	88,435	
8	TH	7,607,070	240	12,874.0	14.7	88,435	
9	F	7,628,113	390	21,043.0	17.0	102,272	
10	S	7,649,711	410	21,598.0	19.3	116,109	
11	SU	7,663,129	240	13,418.0	19.3	116,109	
12	M	7,675,129	240	12,000.0	21.6	129,946	
13	T	7,687,899	240	12,770.0	21.6	129,946	
14	W	7,700,419	240	12,520.0	21.6	129,946	
15	TH	7,712,777	240	12,358.0	21.6	129,946	
16	F	7,724,983	240	12,206.0	22.8	136,864	
17	S	7,737,137	240	12,154.0	22.8	136,864	
18	SU	7,749,182	240	12,045.0	22.8	136,864	
19	M	7,761,582	240	12,400.0	23.9	143,782	
20	T	7,780,533	380	18,951.0	26.2	157,619	
21	W	7,792,325	240	11,792.0	26.2	157,619	
22	TH	7,804,255	240	11,930.0	26.2	157,619	
23	F	7,816,283	240	12,028.0	27.3	164,237	
24	S	7,828,314	240	12,031.0	27.3	164,237	
25	SU	7,839,961	240	11,647.0	27.3	164,237	
26	M	7,851,958	240	11,997.0	27.3	164,237	
27	T	7,863,563	240	11,605.0	28.5	171,456	
28	W	7,875,108	240	11,545.0	29.6	178,074	
29	TH	7,886,749	240	11,641.0	29.6	178,074	
30	F	7,898,449	240	11,700.0	29.6	178,074	

<i>LAST WATER METER READING OF PREVIOUS MONTH</i>	7,506,998
<i>LAST T-4 STORAGE (GALS) READING OF PREVIOUS MONTH</i>	116,109

TOTAL RUN TIME (min)	7,660
TOTAL GALLONS TRANSFERED	391,451

AVERAGE PUMP RATE - GPM	51.1
AVERAGE PUMP RATE - GPH	3,066.2
AVERAGE DAILY STORAGE (GALS)	138,157

MONTHLY OPERATIONS REPORT FOR WELL #2

September-16

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	COMMENTS
1	TH	0	0	0	SHUT DOWN
2	F	0	0	0	
3	S	0	0	0	
4	SU	0	0	0	
5	M	0	0	0	
6	T	0	0	0	
7	W	0	0	0	
8	TH	0	0	0	
9	F	0	0	0	
10	S	0	0	0	
11	SU	0	0	0	
12	M	0	0	0	
13	T	0	0	0	
14	W	0	0	0	
15	TH	0	0	0	
16	F	0	0	0	
17	S	0	0	0	
18	SU	0	0	0	
19	M	0	0	0	
20	T	0	0	0	
21	W	0	0	0	
22	TH	0	0	0	
23	F	0	0	0	
24	S	0	0	0	
25	SU	0	0	0	
26	M	0	0	0	
27	T	0	0	0	
28	W	0	0	0	
29	TH	0	0	0	
30	F	0	0	0	

LAST WATER METER READING OF PREVIOUS MONTH	0
LAST HOUR METER READING OF PREVIOUS MONTH	0.0

Total Monthly Production (Gallons)	0
Total Pump Run time (Hours)	0.0
Average GPH Rate of Production	0

Average Daily Production (Gallons)	#DIV/0!
Percent of time in operation	#DIV/0!
Average GPM Rate of Production	0.0

MONTHLY OPERATIONS REPORT FOR WELL #4

September-16

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	TANK 2 LEVEL IN FT	TANK 2 LEVEL IN GALS	COMMENTS
1	TH	25,007,374	72,660.3	145	11.4	30,000	
2	F	25,052,425	72,684.3	145	11.4	30,000	
3	S	25,099,300	72,707.5	145	12.5	32,895	
4	SU	25,142,437	72,732.6	145	12.5	32,895	
5	M	25,185,650	72,756.0	145	12.5	32,895	
6	T	25,228,837	72,780.5	145	9.0	23,684	
7	W	25,275,118	72,805.1	145	9.0	23,684	
8	TH	25,317,370	72,828.5	145	12.5	32,895	
9	F	25,363,876	72,853.7	145	13.7	36,053	
10	S	25,406,572	72,876.1	145	14.8	38,948	
11	SU	25,449,700	72,900.3	145	11.4	30,000	
12	M	25,492,968	72,924.0	145	13.7	36,053	
13	T	25,539,270	72,949.2	145	13.7	36,053	
14	W	25,586,866	72,975.0	145	12.5	32,895	
15	TH	25,629,262	72,998.0	145	11.4	30,000	
16	F	25,670,404	73,020.3	145	11.4	30,000	
17	S	25,716,965	73,047.1	145	10.1	26,579	
18	SU	25,765,465	73,071.7	145	8.0	21,053	
19	M	25,804,177	73,092.2	145	13.7	36,053	
20	T	25,849,375	73,117.1	145	10.1	26,579	
21	W	25,892,149	73,140.3	145	10.1	26,579	
22	TH	25,938,797	73,165.5	145	12.5	32,895	
23	F	25,983,337	73,189.7	145	13.7	36,053	
24	S	26,070,584	73,212.8	145	13.7	36,053	
25	SU	26,113,716	73,236.1	145	11.4	30,000	
26	M	26,159,441	73,260.6	145	10.1	26,579	
27	T	26,204,650	73,258.2	145	10.1	26,579	
28	W	26,248,518	73,309.7	145	9.0	23,684	
29	TH	26,291,697	73,335.4	145	12.5	32,895	
30	F	26,338,410	73,356.3	145	12.5	32,895	
<i>LAST WATER METER READING OF PREVIOUS MONTH</i>							24,965,070
<i>LAST HOUR METER READING OF PREVIOUS MONTH</i>							72,637.6
<i>LAST T-2 STORAGE (GALS) READING OF PREVIOUS MONTH</i>							30,000
Total Monthly Production (Gallons)							1,373,340
Total Pump Run time (Hours)							718.7
Average GPH Rate of Production							1,911
Average Daily Production (Gallons)							45,778
Percent of time in operation							100%
Average daily storage (gals)							30,781
Average GPM Rate of Production							31.8

MONTHLY OPERATIONS REPORT FOR WELL #6

September-16

DATE	DAY	WATER METER READING	HOUR METER READING	AM SYS BACK PSI	GPH RATE SET	WELL TIMER COMMENTS
1	TH	103,772,877	59,503.3	250	MAX	
2	F	103,783,427	59,510.5	250	MAX	
3	S	103,793,682	59,517.0	250	MAX	
4	SU	103,803,042	59,524.3	250	MAX	
5	M	103,812,402	59,530.3	250	MAX	
6	T	103,821,762	59,537.0	250	MAX	
7	W	103,834,522	59,545.8	250	MAX	
8	TH	103,847,896	59,556.0	250	MAX	
9	F	103,871,106	59,571.1	250	MAX	
10	S	103,892,620	59,586.5	250	MAX	
11	SU	103,912,778	59,600.2	250	MAX	
12	M	103,932,938	59,614.0	250	MAX	
13	T	103,940,385	59,619.1	250	MAX	
14	W	103,947,846	59,624.3	250	MAX	
15	TH	103,952,340	59,627.3	250	MAX	
16	F	103,956,833	59,630.4	250	MAX	
17	S	103,961,153	59,633.8	250	MAX	
18	SU	103,965,834	59,636.6	250	MAX	
19	M	103,996,231	59,657.6	250	MAX	
20	T	104,001,486	59,661.2	250	MAX	
21	W	104,008,927	59,666.3	250	MAX	
22	TH	104,017,442	59,672.0	250	MAX	
23	F	104,025,956	59,678.0	250	MAX	
24	S	104,032,757	59,682.3	250	MAX	
25	SU	104,039,957	59,687.1	250	MAX	
26	M	104,047,157	59,692.6	250	MAX	
27	T	104,054,236	59,697.5	250	MAX	
28	W	104,061,317	59,702.3	250	MAX	
29	TH	104,071,241	59,709.2	250	MAX	
30	F	104,081,162	59,716.1	250	MAX	

<i>LAST WATER METER READING OF PREVIOUS MONTH</i>	103,764,853
<i>LAST HOUR METER READING OF PREVIOUS MONTH</i>	59,497.7

TOTAL MONTHLY PRODUCTION (GALS)	316,309
TOTAL PUMP RUN TIME (HOURS)	218.4
AVERAGE GPH RATE OF PRODUCTION	1,448

AVERAGE DAILY PRODUCTION (GALS)	10,544
PERCENT OF TIME IN OPERATION	30%
AVERAGE GPM RATE OF PRODUCTION	24.1